



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 31, 2017

Address: Water Management Services, Inc.
103 Cat Swamp Road
Hackettstown, NJ 07840

Project: Kittatinny High School

Sample description: Drinking Water / 1st Draw / DWSC3067-1
Sample location: WC-3-C
Sampled by: M. Batalin
Sample date: 04/30/17
Time: 05:57
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	12:45	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-2
Sample location: WC-1-C
Sampled by: M. Batalin
Sample date: 04/30/17
Time: 05:55
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-3
Sample location: TL-BOE
Sampled by: M. Batalin
Sample date: 04/30/17
Time: 06:22
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-4
Sample location: DW-1-A
Sampled by: M. Batalin
Sample date: 04/30/17
Time: 06:07
Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	25.0 µg/L	15 µg/L	05/20/17	13:23	2	4.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-5
 Sample location: WC-7-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:29
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-6
 Sample location: WC-4-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:30
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-7
 Sample location: WC-3-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:29
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-8
 Sample location: WC-9-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:35
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:45	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-9
 Sample location: WC-1-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:27
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	13:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-10
 Sample location: WC-10-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:36
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-11
 Sample location: WC-5-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:26
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:07	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-12
 Sample location: WC-8-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:37
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-13
 Sample location: WC-6-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:24
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-14
 Sample location: WC-11-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:36
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-15
 Sample location: WC-2-E
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:28
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:29	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-16
 Sample location: DW-3-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:16
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:35	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-17
 Sample location: WC-2-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:13
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:41	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-18
 Sample location: DW-4-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:19
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	14:47	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-19
 Sample location: DW-5-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:23
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-20
 Sample location: WC-6-0
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:22
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:16	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-21
 Sample location: WC-1-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:11
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:38	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-22
 Sample location: DW-7-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:44
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:44	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-23
 Sample location: DW-8-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:45
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:49	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-24
 Sample location: WC-9-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:41
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	15:55	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-25
 Sample location: WC-10-D
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:41
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:01	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-26
 Sample location: FD-2-Kitchen
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:08
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:07	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-27
 Sample location: FD-1-Kitchen
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:10
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.56 µg/L	15 µg/L	05/20/17	16:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-28
 Sample location: TL-24-A-Library
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:50
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	10.9 µg/L	15 µg/L	05/20/17	16:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-29
 Sample location: NS-A-Nurse's Office
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:49
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.64 µg/L	15 µg/L	05/20/17	16:29	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-30
 Sample location: DW-2-A
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:08
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.08 µg/L	15 µg/L	05/20/17	16:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-31
 Sample location: WC-3-A
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:09
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.03 µg/L	15 µg/L	05/20/17	16:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-32
 Sample location: TL-A-F-Faculty Room
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:20
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.35 µg/L	15 µg/L	05/20/17	16:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-33
 Sample location: B76/34
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:12
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.23 µg/L	15 µg/L	05/20/17	16:51	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-34
 Sample location: WC-2-B
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:16
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	16:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-35
 Sample location: WC-1-B
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:15
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	17:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-36
 Sample location: TL-A-Mailroom
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:08
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.48 µg/L	15 µg/L	05/20/17	17:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-37
 Sample location: TL-38-C
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:02
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.50 µg/L	15 µg/L	05/20/17	17:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-38
 Sample location: WC-6-C
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:03
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	17:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-39
 Sample location: DW-2-C
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:55
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.19 µg/L	15 µg/L	05/20/17	17:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-40
 Sample location: WC-5-C
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 06:01
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWSC3067-41
 Sample location: IM-1-Trainer's Office
 Sampled by: M. Batalin
 Sample date: 04/30/17
 Time: 05:47
 Analyst: M. Furrey

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	05/20/17	18:10	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

June 6, 2017
 Date